Job Na	me/Lo	cation:
--------	-------	---------

Date

-	u	Ľ	-	• •	
-	-		•		

PO No.:

Architect:

Engr:

Rep: (Company)

LA120HSV5

Single Zone Art Cool Mirror Wall Mount

Outdoor Unit (ODU) - LSU120HSV5, Indoor Unit (IDU) - LAN120HSV5

Performance:

Cool	ling:
CUU	mg.

Caaling Consoits	
Cooling Capacity	
(Min~Rated~Max) (Btu/h)	1,023 ~ 12,000 ~ 13,785
SEER	22.7
EER	12.5
SEER - Seasonal Energy Efficiency Ratio	EER - Energy Efficiency Ratio

Heating:

Heating Capacity	
(Min~Rated~Max) (Btu/h)	1,023 ~ 13,600 ~ 22,178
HSPF	11.4
Max. Heating @ Indoor 70°F DB	
Outdoor 19°F DB / 17°F WB	13,810 (102%)
Outdoor 6°F DB / 5°F WB	11,930 (88%)
Outdoor -3°F DB / -4°F WB	10,360 (76%)
HSPF - Heating Seasonal Performance Factor	Heating Nominal Test Conditions:

g Nominal Test Conditions: Indoor: 80°F DB / 67°F WB Outdoor: 95°F DB / 75°F WB

Indoor: 70°F DB / 60°F WB Outdoor: 47°F DB / 43°F WB

Outdoor Unit:

MOP (A)		15
MCA (A)		10
Cooling / Heating Rated Amps (A)		7.4 / 7.4
Compressor (A)		7
Fan Motor (A)		0.4
MOP - Maximum Overcurrent Protection	MCA - Minimum Circuit Ampacity	

Total Power Input:

Cooling Power Input (kW)	0.96
Heating Power Input (kW)	1.04

Piping:

Liquid Line (in., O.D.)	ø1/4
Vapor Line (in., O.D.)	ø3/8
Additional Refrigerant (oz./ft.)	0.22
Min. / Max. Pipe Length (ft.) ²	9.8 / 82
Piping Length (no add'l refrig., ft.)	41
Max. Elevation (ft.)	49.2

Controls Features:

• 24-Hour on/off timer Condensate Sensor 4-Way auto swing Auto changeover Connection • Inverter (variable speed Auto restart compressor) • IDU compatible with Multi F ODUs Jet cool/Jet heat
Built-in low ambient standard, down to 14°F (cooling mode) Smart Diagnosis
3M Micro Filter

Ontional Accessories

optional Accessories.	
☐ MultiSITE™ CRC1 - PREMTBVC0	AC Smart I
MultiSITE CRC1+ - PREMTBVC1	PBACNA00
MultiSITE Comm. Mgr PBACNBTROA	ACP IV BAC
PI-485 - PMNFP14A1	🗌 Base Pan H
Dry Contact - PDRYCB300	Low Ambie
LonWorks [®] Gateway - PLNWKB100	to 0°E) - 71

Self-cleaning indoor coil

- Sleep mode
 Cooling only function
 Built-in Wi-Fi via Smart
- ThinQ app Built-in base pan heater
- (9/12k; optional for 18k)



Resubmit

Other_

For:

GC:

Mech:

(Project Manager)

File

Approval

Tag #:



Operating Range:

Outdoor Unit:	
Cooling (°F DB)	14 ~ 118
Heating (°F WB)	-4 ~ +65
Indoor Unit:	
Cooling (°F WB)	53 ~ 75
Heating (°F DB)	60 ~ 86
Electrical:	
Power Supply (V ¹ /Hz/Ø)	208-230/60/1
System Data:	
Refrigerant Type	R410A
Refrigerant Control	EEV
Refrigerant Charge (lbs.)	2.21
ODU Sound Pressure	
(Cooling / Heating) (±3 dB[A]) ³	45 / 48
IDU Sound Pressure	
Cooling (H/M/L/Sleep) (±3 dB[A]) ³	39 / 33 / 23 / 19
Heating (H/M/L) (±3 dB[A]) ³	39 / 33 / 23
ODU Net / Shipping Weight (lbs.)	74.1 / 78.9
IDU Net / Shipping Weight (Ibs.)	20.5 / 25.6
Heat Exchanger Coating	GoldFin™
Fan:	
ODU Type	Propeller
IDU Type	Cross Flow
Fan Speeds (Fan/Cool/Heat)	6/6/6
Quantity (ODU + IDU)	1+1
Motor/Drive	Brushless Digitally Controlled/Direct
ODU Max. Air Flow Rate (CFM)	1,165
IDU Air Flow	
Cooling, Max/H/M/L (CFM)	459 / 338 / 317 / 194
Heating, Max/H/M/L (CFM)	459 / 338 / 317 / 229
Dehumidification (pts./hr.)	2.7
Notes:	

Notes:

Notes: 1. Acceptable operating voltage: 187V-253V. 2. Piping lengths are equivalent. 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745. 4. All communication / connection (power) cable from the outdoor unit to the indoor unit is field supplied and is to be minimum four-conductor, 18 AWG, stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor unit only), and must comply with applicable local and national codes. 5. See Engineering Manual for sensible and latent capacities. 6. Power wiring cable size must comply with the applicable local and national code. 7. The indoor unit comes with a dry helium charge. 8. This data is rated 0 ft. above sea level, with 24.6 ft. of refrigerant line and a 0 ft. level difference between ourtdoor and indoor units.

Intertek

This data is faced of it. above sea level, with 24.0 ft. of refingerant line and a of it, level difference between outdoor and indoor units.
 Must follow installation instructions in the applicable LG installation manual.
 Must follow installation with Multi F systems.
 BACnet* is a registered trademark of ASHRAE. LonWorks* is a trademark of Echelon Corporation.





IV BACnet[®] Gateway -00 Cnet Gateway - PQNFB17C2 Heater for 18k - PQSH1201 ent Wind Baffle Kit (Cooling to 0°F) - ZLABGP01A

For a complete list of available accessories, contact your LG representative.

For continual product development, LG reserves the right to change specifications without notice. SB_SZ_4 © LG Electronics U.S.A., Inc., Englewood Cliffs, NJ. All rights reserved. "LG Life's Good" is a registered trademark of LG Corp. /www.lghvac.com

SB_SZ_Art_Cool_Mirror_LA120HSV5_2017_12_08_085358 Page 1 of 3



