Job Name/Location: For: File Resubmit Date: **Approval** Other. PO No.: GC: Architect: Mech: Engr: Rep: (Project Manager) LS120HSV5 Single Zone High Efficiency Standard Wall Mount Outdoor Unit (ODU) - LSU120HSV5, Indoor Unit (IDU) - LSN120HSV5 Performance: Cooling: **Outdoor Unit:** Cooling (°E DB) **Cooling Capacity** 1,023 ~ 12,000 ~ 13,785 (Min~Rated~Max) (Btu/h) **EER** 12.5 SEER - Seasonal Energy Efficiency Ratio EER - Energy Efficiency Ratio Heating (°F DB) Heating: **Electrical: Heating Capacity** (Min~Rated~Max) (Btu/h) 1,023 ~ 13,600 ~ 22,178 **HSPF System Data:** 11.4 Max. Heating @ Indoor 70°F DB 13,810 (102%) Outdoor 19°F DB / 17°F WB Outdoor 6°F DB / 5°F WB 11,930 (88%) Outdoor -3°F DB / -4°F WB 10,360 (76%) HSPF - Heating Seasonal Performance Factor Cooling Nominal Test Conditions: **Heating Nominal Test Conditions:** Indoor: 80°F DB / 67°F WB Indoor: 70°F DB / 60°F WB Outdoor: 95°F DB / 75°F WB Outdoor: 47°F DB / 43°F WB **Outdoor Unit:**

MOP (A)		15
MCA (A)		10
Cooling / Heating Rated Amps (A)		7.4 / 7.4
Compressor (A)		7
Fan Motor (A)		0.4
MOP - Maximum Overcurrent Protection	MCA - Minimum Circuit Ampacity	

Total Power Input:

Cooling Power Input (kW)	0.96
Heating Power Input (kW)	1.04

Piping:

Liquid Line (in., O.D.)	ø1/4
Vapor Line (in., O.D.)	ø3/8
Additional Refrigerant (oz./ft.)	0.22
Min. / Max. Pipe Length (ft.) ²	9.8 / 82
Piping Length (no add'l refrig., ft.)	41
Max. Elevation (ft.)	49.2

Controls Features:

- 24-Hour on/off timer
- 4-Way auto swingAuto changeover
- Auto restart
- Jet cool/Jet heatBuilt-in low ambi-
- ent standard, down to 14°F (cooling mode)
- Condensate Sensor
- Connection • Inverter (variable speed
- compressor)
- IDU compatible with Multi F ODUs
- Smart Diagnosis
 3M Micro Filter
- Self-cleaning indoor coil
- Sleep mode
 Cooling only function
 Built-in Wi-Fi via Smart
- ThinQ app
 Built-in base pan heater
- (9/12k; optional for 18k)

Optional Accessories:

MultiSITE™ CRC1 - PREMTBVC0	☐ AC Smart IV BACnet® Gateway -
☐ MultiSITE CRC1+ - PREMTBVC1	PBACNA000
☐ MultiSITE Comm. Mgr PBACNBTR0A	☐ ACP IV BACnet Gateway - PQNFB17C2
☐ PI-485 - PMNFP14A1	☐ Base Pan Heater for 18k - PQSH1201
☐ Dry Contact - PDRYCB300 ☐ LonWorks® Gateway - PLNWKB100	☐ Low Ambient Wind Baffle Kit (Cooling
LOHWORKS Galeway - PLNWKB100	to 0°F) - ZLABGP01A





Tag #:



60 ~ 86

Operating Range:

Cooling (°F DB)	14 ~ 118
Heating (°F WB)	-4 ~ +65
Indoor Unit:	
Cooling (°F WB)	53 ~ 75

Power Supply (V)/Hz/Ø)	208-230/60/1

Refrigerant Type	R410A
Refrigerant Control	EEV
Refrigerant Charge (lbs.)	2.21
ODU Sound Pressure	
(Cooling / Heating) (±3 dB[A]) ³	45 / 48
IDU Sound Pressure	
Cooling (H/M/L/Sleep) (±3 dB[A]) ³	39 / 33 / 23 / 19
Heating (H/M/L) (±3 dB[A]) ³	39 / 33 / 23
ODU Net / Shipping Weight (lbs.)	74.1 / 78.9
IDU Net / Shipping Weight (lbs.)	18.3 / 25.6
Heat Exchanger Coating	GoldFin™
	Refrigerant Control Refrigerant Charge (lbs.) ODU Sound Pressure (Cooling / Heating) (±3 dB[A])³ IDU Sound Pressure Cooling (H/M/L/Sleep) (±3 dB[A])³ Heating (H/M/L) (±3 dB[A])³ ODU Net / Shipping Weight (lbs.) IDU Net / Shipping Weight (lbs.)

Fan:

ODU Type	Propeller
IDU Type	Cross Flow
Fan Speeds (Fan/Cool/Heat)	6/6/6
Quantity (ODU + IDU)	1+1
Motor/Drive	Brushless Digitally Controlled/Direct
ODU Max. Air Flow Rate (CFM)	1,165
IDU Air Flow	
Cooling, Max/H/M/L (CFM)	459 / 338 / 317 / 194
Heating, Max/H/M/L (CFM)	459 / 338 / 317 / 229
Dehumidification (pts./hr.)	2.7

Notes:

- 1. Acceptable operating voltage: 187V-253V.
 2. Piping lengths are equivalent.
 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.
- A All communication / connection (power) cable from the outdoor unit to the indoor unit is field supplied and is to be minimum four-conductor, 18 AWG, stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor unit only), and must comply with applicable local and national codes.

 5. See Engineering Manual for sensible and latent capacities.

 6. Power wiring cable size must comply with the applicable local and national code.

 7. The indoor unit comes with a dry helium charge.

 8. This data is rated 0 ft. above sea level, with 24.6 ft. of refrigerant line and a 0 ft. level difference between

- outdoor and indoor units.

 9. Must follow installation instructions in the applicable LG installation manual.

 10. Multi compatible 18k IDUs include socket adapters for refrigerant pipe connections with Multi F systems.
- BACnet® is a registered trademark of ASHRAE. LonWorks® is a trademark of Echelon Corporation








LS120HSV5


Single Zone High Efficiency Standard Wall Mount
Outdoor Unit (ODU) - LSU120HSV5, Indoor Unit (IDU) - LSN120HSV5





Tag No.: ______
Date: _____


PO No.:











LS120HSV5

Single Zone High Efficiency Standard Wall Mount
Outdoor Unit (ODU) - LSU120HSV5, Indoor Unit (IDU) - LSN120HSV5



Tag No.: ______
Date:

PO No.:

